

# CITY OF MILPITAS

Building & Safety Department  
455 E. Calaveras Blvd.  
Milpitas, CA 95035  
408-586-3240  
[www.ci.milpitas.ca.gov](http://www.ci.milpitas.ca.gov)



## COMMERICAL SANITARY SEWER LATERAL INSPECTION CHECKLIST

---

- Cleanout shall be installed per City of Milpitas Standard Drawing No.618 and 602
- Cleanout box shall be Christy G-5 Box
- G5C Lid and G5GR or approved equal with "C.O." or "S" marking
- Cast iron traffic cover required in sidewalk or driveway
- Plug shall be approved and labeled
- Riser shall be the same size as sewer lateral
- Building sewer drainage constructed of approved materials
- Minimum grade at lateral shall be ¼" per foot ( 2 percent )
- Building sewer cleanouts shall be extended to grade and comply with CPC Section 707
- Building sewer shall be tested at its points of connection with the Public Sewer and completely filling the building sewer with water from the lowest to the highest point
- Where sidewalk is not contiguous with street curb, cleanout should be placed 6" behind street curb