



**City of Milpitas
Building and Safety Department**

Mailing Address: 455 East Calaveras Boulevard, Milpitas, California
95035-5479 – Tel. 408.586.3240, Fax 408.586.3285 www.ci.milpitas.ca.gov

**Access & Entrance to Working Space in
Multiple Tenancy Building**

Policy:	BDP-EL01
Effective Date:	1/1/2011
Proposed by:	
Last Reviewed/ Revised:	3/1/11
Reviewed/ Revised by:	BK
Approved By:	Keyvan Irannejad P.E. Chief Building Official

In conformance with sections 90.4 and 110.26(C) of the 2010 California Electrical Code, the following interpretation is provided:

“In multiple tenancy buildings, the following access and entrance to electrical equipment are acceptable:

1. All required entrances must be located on the exterior of the building, or
2. Interior public corridor leading directly to building exit.

In single tenancy buildings, the required entrances may be a combination exterior/interior”