



**City of Milpitas
Building and Safety Department**

Mailing Address: 455 East Calaveras Boulevard, Milpitas, California
95035-5479 – Tel. 408.586.3240, Fax 408.586.3285 www.ci.milpitas.ca.gov

**Multiple tenancy branch circuits
and disconnects**

Policy:	BDP-EL02
Effective Date:	03/21/1996
Proposed by:	
Last Reviewed/ Revised:	3/7/2011
Reviewed/ Revised by:	DW
Approved By:	Keyvan Irannejad P.E. Chief Building Official 

**Official Interpretation 2010 CEC Multiple Tenancy Branch
Circuits and Disconnects**

In conformance with sections 90.4, 230.72 (C) and 240.24 (A) and (B) of the 2010 California Electrical Code, the following interpretation is provided:

- 1) Branch circuits shall not be shared between tenants.**
- 2) Where multiple tenancies occur, each tenant shall be provided with (1) approved disconnecting means.**