



**City of Milpitas  
Building and Safety Department**

Mailing Address: 455 East Calaveras Boulevard, Milpitas, California  
95035-5479 – Tel. 408.586.3240, Fax 408.586.3285 [www.ci.milpitas.ca.gov](http://www.ci.milpitas.ca.gov)

**Outlet requirements for offices**

<b>Policy:</b>	BDP-EL03
Effective Date:	02/02/2001
Proposed by:	
Last Reviewed/ Revised:	3/7/2011
Reviewed/ Revised by:	DW
Approved By:	Keyvan Irannejad P.E. Chief Building Official



*Official interpretation 2010 CEC, Outlet requirements commercial and industrial offices*

**In conformance with sections 90.4 and 210.50(B) of the 2010 California Electrical code  
The following interpretation is provided:**

- 1) Office outlets shall be installed in commercial and industrial offices so that no point along the floor line in any wall space is more than 6 feet, measured horizontally from an outlet in that space.