



**City of Milpitas  
Building and Safety Department**

Mailing Address: 455 East Calaveras Boulevard, Milpitas, California  
95035-5479 – Tel. 408.586.3240, Fax 408.586.3285 [www.ci.milpitas.ca.gov](http://www.ci.milpitas.ca.gov)

**Protection of working space clearances  
at electrical equipment**

<b>Policy:</b>	<b>BDP-EL07</b>
Effective Date:	12/7/2011
Proposed by:	LS
Last Reviewed/ Revised:	
Reviewed/ Revised by:	
Approved By:	Keyvan Irannejad P.E. Chief Building Official

As per CEC sec.110.26 (B) working space shall not be used for storage and when in a passageway or general open space shall be suitably guarded.  
To properly identify guarded area provide label on the equipment stating that minimum clear distance, as identified by CEC sec.110.26(A), shall be maintained clear and unobstructed. The depth of the working space shall be minimum 36” and the width is 30” or the width of the equipment, whichever is greater.