



**City of Milpitas
Building and Safety Department**

Mailing Address: 455 East Calaveras Boulevard, Milpitas, California
95035-5479 – Tel. 408.586.3240, Fax 408.586.3285 www.ci.milpitas.ca.gov

Disinfection of Potable Water System

Policy:

BDP-PL04

Effective Date:

7/24/2012

Proposed by:

MM

Last Reviewed/
Revised:

Reviewed/
Revised by:

Approved By:

Keyvan Irannejad P.E.
Chief Building Official

New and altered Potable Water Systems shall follow the prescribed method in the code for disinfection of the potable water. 2010 California Plumbing Code section 609.9-609.9.4